



DRY AREA WALL BASE DETAIL

NOTES:

1. ALL PANELS TO BE FM APPROVED, POLYPHEN, KINGSPAN, OR METECNOPANEL.
2. 4.8mm STEEL RIVETS MAY BE USED IN LIEU OF 8gX16mm SELF TAPPING SCREWS.
3. PANEL TO PANEL JOINTS TO BE SEALED WITH FOSROC OR SELLEYS COLDROOM MASTIC OR SIMILAR



Retracom

Insulated Panel Systems

60 Magnesium Dr Crestmead, QLD. 4132
Tel: (07) 3803 4733, Fax: (07) 3803 4711
Email: sales@retracom.com.au

Title: DRY AREA WALL BASE DETAIL – FM STANDARD

For: ... Job No.: ...

Date Drawn: 21-08-06	By: C.L.	Dwg. No.:	Revision:
Scale: N.T.S.	Sheet (2 of 4) A4	FM-BASE-03	...
		Sheet 1 of 1	...